

NOTES TO G.C.

- Give special attention to:
 - Any obstructions to ceiling pockets & cables (i.e. ducts, sprinkler pipes, drain pipes, electrical conduits, etc.).
 - Tolerances of fixed walls & finished floor.
 - Removable ceiling tile for top of pocket.
- Acoustic performance:

Skyfold Classic

North America: STC: 51 as per ASTM E90

Europe: Rw: 51 as per ISO 140-3, Part 3 & ISO 717-1:2

Skyfold Classic Elite

North America: STC: 57 as per ASTM E90

Europe: Rw: 56 as per ISO 140-3, Part 3 & ISO 717-1:2

Skyfold Classic NR

North America: STC: 50 as per ASTM E90

NRC: 0.65 as per C423

Europe: Rw: 49 as per ISO 140-3, Part 3 & ISO 717-1:2

SAC: 0.65 as per ISO 354.

- Panel finish: XXXXXXXXXXXXXXXXXXXXXXXX.

- Skyfold requires two 24" x 24" (610 x 610) (minimum) access panels in acoustic ceiling directly beside motor for installation & maintenance of system. Not required if finished ceiling is suspended ceiling tiles.

- Drive unit to be installed prior to construction of acoustic barrier & pocket. All pocket construction (gypsum, suspended ceiling tile, framing, etc.) is by others.

- The floor underneath the wall along its axis must be flat to within 1/4" [6] over the entire length of the wall. A peak to valley undulation of ± 1/4" [6] must not be closer together than 24" [610]. A peak to valley undulation of ± 1/8" [3] must not be closer together than 12" [305].

- Do not scale from this drawing. All dimensions must be verified on site.

- Dimensions in [] are in millimeters (mm) unless noted otherwise.

****C-channel designation:**

North & South America = C8 x 11.5 [C200 x 17]
Europe = C200 x 75
Asia = C200 x 80

NOTE:
SEE DRAWINGS R811826 & R811827 FOR 17'-0" MINIMUM TO 24'-0" MAXIMUM (5180 MINIMUM TO 7315 MAXIMUM) LONG WALL CONDITIONS.

SEE DRAWINGS S1419 & S1420 FOR 24'-0" MINIMUM TO 36'-0" MAXIMUM (7315 MINIMUM TO 10973 MAXIMUM) LONG WALL CONDITIONS.

THIS DRAWING IS INTENDED AS A GUIDE. IN ALL CASES SKYFOLD SHOP DRAWINGS SPECIFIC TO EACH PROJECT ARE REQUIRED FOR FINAL BUILD-TO DIMENSIONS.

AUTOMATED SKYFOLD DETAIL

Project:


TYPICAL SKYFOLD WALL

11'-10" min to 17'-0" max [3605 min to 5180 max]
x 9'-0" max [2745 max] B.O. Pocket
Micro drive unit

PANEL & POCKET DETAILS

Contractor:


Drawn by	Date	Approved by	Date
SKYSD project No.	Scale	As noted	Sheet No.
Drawing No.			2 of 2
R811738			Revision



C | ELEVATION - WALL DOWN


R811737 | SCALE: 3/8" = 1'-0"

NOTE: FINISHED FLOOR
-3/4" [-6] FROM FLAT LEVEL
FIXED WALL
-3/4" [-6] FROM FLAT VERTICAL




3 | POCKET DETAIL

R811738 | SCALE: 1/2" = 1'-0"



2 | END SEAL DETAIL

R811737 | SCALE: 1/2" = 1'-0"



4 | FLOOR SEAL DETAIL

R811738 | SCALE: 1/2" = 1'-0"